**US Army Corps
of Engineers®**
Engineer Research and
Development Center

U.S. Army Corrosion Prevention and Control Program

Innovative Corrosion-Resistant Coatings for Heat Distribution Piping at Fort Jackson

Charles P. Marsh, Alfred D. Beitelman, and Ryan J. Franks

June 2007

Innovative Corrosion-Resistant Coatings for Heat Distribution Piping at Fort Jackson

Charles P. Marsh, Alfred D. Beitelman, and Ryan J. Franks

*Engineer Research and Development Center
Construction Engineering Research Laboratory
2902 Newmark Drive
Champaign, IL 61822*

Final report

Approved for public release; distribution is unlimited.

Prepared for U.S. Army Installation Management Command (IMCOM)
Arlington, VA 22202

Under U.S. Army CPC Project IMA-2

Abstract: Heat distribution systems are an integral part of military facility and installation infrastructure. These systems include numerous manholes that represent weak points in the overall efficiency, reliability, and service life of heating infrastructure. This report discusses the demonstration of an insulating ceramic paint and primer applied to coat manholes, piping, and appurtenances at Fort Jackson, SC, and the results obtained. The ceramic paint helps to prevent corrosion and heat loss while also significantly mitigating heat-related safety hazards to workers in the treated manhole. Because these issues are important operational concerns for every military facility, ceramic coatings represent a beneficial facility engineering technology that should be considered for wider adoption in heat distribution systems.

DISCLAIMER: The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official endorsement or approval of the use of such commercial products. All product names and trademarks cited are the property of their respective owners. The findings of this report are not to be construed as an official Department of the Army position unless so designated by other authorized documents.

DESTROY THIS REPORT WHEN NO LONGER NEEDED. DO NOT RETURN IT TO THE ORIGINATOR.

Contents

Introduction	iv
Executive Summary	v
Unit Conversion Factors.....	vi
1 Background.....	1
2 Lessons Learned.....	3
3 Technical Investigation.....	4
September 2005 coating application	4
Site 1 – Corner of Marion and Hill Streets.....	4
Site 2 – Corner of Scales and Hood Streets.....	6
Site 3 – Sumter Street behind Building 2179.....	7
August 2006 field evaluation	8
Site 1 – Corner of Marion and Hill Streets.....	8
Site 2 – Corner of Scales and Hood Streets.....	9
Site 3 – Sumter Street behind Building 2179.....	9
Test panel evaluation.....	10
4 Metrics.....	11
5 Economic Summary	12
Projected return on investment.....	12
Assumptions	12
6 Recommendation	13
7 Implementation	14
8 Conclusion.....	15
Appendix A: Project Management Plan (PMP)	16
Appendix B: Test Panel Results.....	30
Appendix C: Third-Party ROI Report.....	36
Report Documentation Page	

Introduction

This demonstration was performed for the U.S. Army Installation Management Command (IMCOM) under U.S. Army Corrosion Prevention and Control (CPC) Program Project IMA-2; Military Interdepartmental Purchase Requests MIPR5CCERB1011 and MIPR5CROBB1012, dated 15 December 2005. The proponent was the U.S. Army Office of the Assistant Chief of Staff for Installation Management (ACSIM). The technical monitors were Paul M. Volkman (IMPW-E) and David N. Purcell (DAIM-FDF). The stakeholders are Mr. Smith (Fort Jackson DPW), Mr. Volkman, Steve Jackson (IM-SERO), Mr. Purcell (DAIM-FDF), as well as Tri-Services WIPT representatives, Ms. Nancy Coleal (AFCESA/CESM) and Tom Tehada (NFESCX). The customer was Mr. Smith, Fort Jackson DPW.

The work was performed by the Materials and Structures Branch (CF-M) of the Facilities Division (CF), Construction Engineering Research Laboratory – Engineer Research and Development Center (ERDC-CERL). The Program Manager for the ERDC-CERL CPC Program was Dr. Ashok Kumar. The ERDC-CERL CPC Program Project Officer was Vincent F. Hock (CEERD-CF-M) and the Associate Project Officer was Dr. Charles P. Marsh (CEERD-CF-M). Dr. Marsh was assisted by Alfred D. Beitelman (CEERD-CF-M) of the Paint Technology Center at ERDC-CERL. The coatings work was done under contract with Twin Cities, Inc., Columbia, SC. At the time of coating application quality assurance was performed on site by Mr. Beitelman. Economic analysis was performed by The PERTAN Group, Champaign, IL. The project was facilitated by the assistance and cooperation of Steve Smith, Fort Jackson Directorate of Public Works, and George Dibb, Fort Jackson Department of Logistics and Engineering.

At the time this report was prepared, the Chief of the ERDC-CERL Materials and Structures Branch was Vicki L. Van Blaricum (CEERD-CF-M), the Chief of the Materials and Structures Branch was L. Michael Golish, (CEERD-CF), and the Technical Director for Installations was Martin J. Savoie (CEERD-CV-ZT). The Deputy Director of ERDC-CERL was Dr. Kirankumar Topudurti and the Director was Dr. Ilker Adiguzel.

The Commander and Executive Director of ERDC was COL Richard B. Jenkins and the Director was Dr. James R. Houston.

Executive Summary

An innovative ceramics-based thermal barrier coating technology was implemented at Fort Jackson, SC. The coating was monitored for 1 year through periodic inspections, including assessment of coated sample specimens exposed to the interior manhole operating environment. The coating durability was found to be excellent, and the usually corrosive heat distribution system (HDS) manhole environment mitigated. The return on investment was found to be 58.

The primary lessons learned were that it is necessary to arrange for coating application during prescheduled system shutdowns (which typically occur only during short periods in the spring and fall), and that the addition of extra approved conventional insulation can further improve the economic benefits of the coating. The economic analysis base comparison case assumed the pipes to be fully insulated, but it is typical for insulation to be missing from one or more portions of HDS manhole piping.

When this coating is used, it is recommended that the existing pipes be partially re-insulated so as to approximate the thermal properties of a newly constructed system.

Unit Conversion Factors

Multiply	By	To Obtain
degrees Fahrenheit	$(F-32)/1.8$	degrees Celsius
feet	0.3048	meters
gallons (U.S. liquid)	3.785412 E-03	cubic meters
inches	0.0254	meters
mils	0.0254	millimeters
square feet	0.09290304	square meters

1 Background

Many U.S. Army installations are served by district heat distribution systems (HDSs) that provide space heating and hot water to the facilities. HDSs are large, complex networks of highly interdependent components, and the deterioration of one component affects the performance and deterioration rate of nearby or related components.

Manholes usually serve as valved take-offs to individual buildings, and they house many critical HDS components. Carrier pipes inside manholes are usually wrapped with insulation to prevent heat loss and to protect service personnel from burns upon entering the manhole. Nevertheless, during routine heat distribution service, the localized environment inside HDS manholes is typically hot and humid, which is severely corrosive to exposed steel. Furthermore, water tends to infiltrate the manhole from outside or through pinhole leaks in pipes. When water collects in the manhole or becomes trapped within the pipe insulation, corrosivity intensifies and carrier pipes can deteriorate prematurely. As degradation of the insulation and steel accelerate, the useful service life of pipes may decrease from 25 years to as little as 10 or 15 years.

The corrosion of the carrier pipe in the manholes also creates problems that propagate through other components in the same manhole and the connecting pipes.¹ Protecting the carrier pipe inside manholes against corrosion extends the service life of the entire HDS considerably, so it is desirable to have a cost-effective coating alternative to protect the carrier pipes against corrosion while additionally providing enough thermal insulation to help protect service personnel inside the manhole. Improvements in worker safety increase the likelihood that maintenance will be performed on a timely basis.

In addition, flooded manholes are at a near-optimal temperature for nucleate boiling, which can result in excessive heat loss. Using conservative unit energy costs, a boiling manhole is estimated to lose from \$50,000 to \$125,000 worth of heat per year if not repaired.² Boiling manholes often

¹ Couch, Robert O. 1993. Underground heat distribution systems. 1993 Federal Section Conference: May 20 – 21, 1993. Arlington, VA: IDCA.

² Marsh, Charles P., and Terrill R. Laughton. June 1998. Boiling Manhole Heat-Loss Calculations.

go uncorrected for years, and their premature failure can only be reversed through expensive repair or replacement projects.

Because HDS manholes are both a critical necessity and a system vulnerability, better methods are needed to protect manhole pipes from corrosion. The Directorate of Public Works at Fort Jackson, SC, the U.S. Army Installation Management Command (IMCOM), and the Office of the Assistant Chief of Staff for Installation Management (ACSIM) have identified heat distribution systems as a critical part of the infrastructure needed to support the installation mission.

The project documented here uses a liquid ceramic coating and primer system to protect bare manhole piping in heat distribution systems. This class of coatings has been used for more than 10 years in industrial settings but is not currently used on HDS manhole piping on Army installations. Upon application of this coating the overall environment will be rendered significantly less corrosive while directly protecting the piping and associated segments.

2 Lessons Learned

One of the primary lessons learned from this work is that the insulating value of the ceramic coating alone is significantly lower than intact conventional insulation. Therefore, it is recommended that a partial amount of approved conventional insulation be used in conjunction with the insulating coating. In a typical situation this will upgrade uninsulated piping both for corrosion protection and improved energy efficiency.

Another lesson learned is that scheduling the coating application can be a significant challenge. It is essential that this coating material be applied to a de-energized system and be given enough time to cure before the HDS system is fully re-energized. A typical HDS services a number of installation customers all year for both space heating and domestic hot water. Scheduled maintenance is usually performed over an interval of about 2 weeks in both the spring and the fall, so these would appear to be the best opportunities to apply the coating.

Also, as based on experience but also applicable to this work, expert inspection during the surface preparation and coating work is essential. Otherwise there is a risk that less than adequate attention will be applied and a poor coating job will result.

3 Technical Investigation

September 2005 coating application

At Fort Jackson a number of manholes were prepared to be primed and subsequently topcoated with the insulating ceramic coating. A number of test panels were placed at each site for periodic sampling and field evaluation in order to monitor the condition of the coating over time. Also, a small ancillary investigation was performed in which a fiberglass mesh laminate material was embedded in the ceramic coating system along a small portion of the manhole piping. The purpose of the side investigation was to observe how the fiberglass reinforcement may affect the performance of the ceramic coating system. Details of the work are presented below.

Site 1 – Corner of Marion and Hill Streets

This pit is approximately 15 ft square and 10 ft deep. It contains dual hot water pipes with a surface temperature on the upper pipe of 182 °F and on the lower pipe of 152 °F. (Chilled water pipes in the pit were not a part of the contract.) Main pipes have an exterior diameter of approximately 6 1/2 in. and a length of 13 ft. There are two large valves on the main pipes and eight smaller valves on side pipes of 1 – 2 in. diameters. Total area to be painted was estimated to be approximately 90 sq ft. The pipes enter the pit from the west and exit to the east in 24 in. conduits. They are fully exposed in the pit. Insulation was removed on Monday (29 August 2005) and surface preparation and priming was conducted on Tuesday. Surface preparation resulted in holes in the conduit on the east end of the pit. Holes in the top of the conduit were numerous. Water squirted from holes in the side on the conduit, causing some delay in surface preparation. A 1 in. pipe plug was removed in an effort to drain the conduit, but after 2 hours water was still squirting from the holes halfway up the side, so the plug was replaced and work continued. Abrasive blasting was conducted using silica sand having a designation of BX12. It had a wide gradation and produced a surface profile (replica tape) of 3.5 – 3.7 mils. Approximately half of a 5 gallon batch of MIL-DTL-24441 Formula 159 (manufactured by BLP Mobile) was mixed, and only a small portion of it was used. Application was with an electrically operated airless spray unit using a 517 tip. Mixing and application went smoothly. Thickness measurements the following day

ranged from 3 – 15 mils with most of the readings in the 7 – 8 mil range. The coating was smooth and had no notable runs, sags, or instances of overspray.

On Thursday morning the initial topcoat was applied by airless spray using a 517 tip. The product, TC HB Ceramic manufactured by Capstone Manufacturing Co., Seattle, WA, was sprayed without thinning. The application had extensive overspray, especially on the west end of the top pipe. Water was added in an effort to smooth out the application. The resulting application had extreme thickness variations. Bubbling was noted on several areas on the upper pipe. (This is the hottest pipe and the thickest application.) Some bubbled areas were removed with a knife shortly after the application and the areas repaired. Other bubbled areas were removed with a knife on Friday. It was noted that adhesion to the primer on the top of the west end of the top pipe was poor. It is thought this was due to the overspray landing on the pipe prior to the paint application. Thickness measurements indicated the topcoat to be as little as 15 mils on undersides and hard to coat areas to near 1/8 in. on the top of some pipe areas. Most application was in the 20 to 30 mil range.

On Friday afternoon the second topcoat was applied by airless spray using a 515 tip. The application had no notable overspray.

After a 3 day weekend the coating thickness was measured on Tuesday, 6 September 2005. A few areas of the topcoat, primarily on the undersides of the pipes, were less than the required 45 mils. In those cases, the thickness was brought up to specification with a brush. Overall, the thickness of the final system is mostly in the 50 – 70 mil range, with some areas on the east end being in excess of the 100 mil capability of the gage.

Temperature measurements were made with both an infrared (IR) thermometer and a contact thermometer. The readings are shown in Table 1.

Table 1. Temperature measurements from site 1 manhole.

Area	IR	Contact
West end	81 – 82	59 - 61
On fiberglass	71 – 75	52 - 55
East end (top)	72 – 78	48 - 55
(bottom)	65 – 66	50 - 51

Site 2 – Corner of Scales and Hood Streets

This pit is approximately 15 ft square and 9 ft deep and contains dual hot water pipes. The surface temperature on the upper pipe is 155 °F and on the lower pipe it is 138 °F. (Chilled water pipes in the pit were not a part of the demonstration.) Pipes entering the pit have a diameter of approximately 6 1/2 in. for 9 ft, at which point the diameter is reduced to 4 1/2 in. for approximately 5 ft. There are 6 in. and 4 in. branches off the main pipes. There are three large valves on the main pipes and five smaller valves on side pipes with 1 in. diameters. The total area to be painted was estimated to be approximately 80 square ft. The pipes enter the pit from the west and exit to the east in 24 in. conduits. They are fully exposed in the pit. Insulation was removed on Monday and surface preparation and priming were conducted on Thursday. An initial probe of rust with a putty knife on the west conduit opened a 2 in. diameter hole. There was concern that abrasive blast of the pipe in the area might perforate the pipe, so minimal blasting was performed within 16 in. of the conduit. All other areas of the pipes were blasted to the SSPC-SP6 (commercial) grade. Blast was conducted with silica sand having a designation of BX12. It had a wide gradation and produced a surface profile (replica tape) of 3.5 – 3.7 mils. A single 3 gallon pail of Wasser MC Zinc, Standard grade batch number 50213 was mixed for application. Only a fraction of this material was used. Application was with an electrically operated airless spray unit using a 517 tip. Mixing and application went smoothly; however, upon drying for several minutes gas bubbles began forming where the application was excessively thick. Thickness measurements the following day ranged from 3.6 – 15 mils, with most of the readings in the 3.6 – 8 mil range. Blistering was limited to a few small areas where the thickness was in excess of 10 mils. The blisters were removed with a razor blade and the coating touched up with a brush.

On Friday afternoon the initial topcoat was applied by airless spray using a 515 tip. The product, TC HB Ceramic manufactured by Capstone Manufacturing Co., Seattle, WA, was thinned with water. The application had no notable overspray, but some sagging was seen on areas of excessive thickness.

After a 3 day weekend the coating thickness was measured on Tuesday, 6 September 2005. A few areas of the topcoat, primarily undersides of the pipes were less than the required 45 mils so the thickness was brought up to specification requirements with a brush. Bubbling was again removed

and touched up with a brush. Overall, the thickness of the final system was mostly in the 50 – 70 mil range, with some areas on the east end exceeding the 100 mil capability of the gage. Much of the excessive thickness was due to the amount of overspray and attempts to smooth the coating.

Temperature measurements were made using both an IR thermometer and a contact thermometer. Readings are shown in Table 2.

Table 2. Temperature measurements from site 2.

Area	IR	Contact
West end	81 – 82	55
On fiberglass	71 – 76	52 - 55
East end (top)	69 – 72	48 - 55
(bottom)	64 – 68	44 - 47

Site 3 – Sumter Street behind Building 2179

This pit is approximately 6 ft square and 8 ft deep. It has two pipes entering from the north and exiting the west. Upon arrival of the contractor the pit had approximately 2 ft of water. The lower pipe was completely submerged and the upper pipe was submerged except for a small amount of insulation. The sump pump was not operational and the electrical outlet near the pit was dead. A new sump pump was purchased and a generator was used to drain the pit. This pit contains dual hot water pipes at ambient temperature. The pipes enter the pit from the north through a 20 in. conduit. They are 3 1/2 in. outside diameter and are reduced to 2 in. before exiting the pit through a 16 in. diameter conduit to the west. The upper pipe is approximately 7 ft long and the lower one is 10 ft. There are two large valves on the main pipes and six small valves on 1 in. side pipes. The total area being painted was estimated to be approximately 50 sq ft. Insulation was removed on Monday and surface preparation and priming were conducted on Wednesday. Blast was conducted with silica sand having a designation of BX12. It had a wide gradation and produced a surface profile (replica tape) of 3.5 – 3.8 mils. Quality of blast met the SSPC SP6 (commercial) grade in all areas. Approximately half of a 5 gallon batch of High Temp 600ZN HA manufactured by Hi-Temp Coatings of Acton, MA, was mixed, and only a small portion of this quantity was used. Mixing was aggravated by the marginal quality of the zinc component. The zinc was packaged in a plastic bag inside a 1 gallon can. Although there was a sack of desiccant in the can, it appeared that moisture had caused the zinc to clump. Application was with an electrically operated airless spray unit us-

ing a 517 tip. Thickness measurements revealed all areas to be in the 2.7 – 12 mil range, with most measurements in the 5 – 6 mil range.

The first topcoat was applied Thursday morning. The product, TC HB Ceramic manufactured by Capstone Manufacturing Co., Seattle, WA, was thinned with water. The application had no notable overspray, but some sagging was seen on areas of excessive thickness. After drying overnight, spots of rust were noted in the recesses of flanges. Thickness measurements of the first topcoat varied widely, from completely missed areas to sagged areas with more than 30 mils of coating, probably due in part to the complicated surfaces and confined work area.

The second topcoat was applied Friday morning.

After a 3 day weekend the coating thickness was measured on Tuesday, 6 September 2005. A few areas of the topcoat, primarily undersides of the pipes, were less than the required 45 mils, so the thickness was brought up to specification requirements with a brush. Overall, the thickness of the final system is mostly in the 60 – 70 mil range.

August 2006 field evaluation

On 27 August 2006 a final observation of the coated HDS manhole pipes was performed. The final set of test panels was retrieved and the condition of the applied coatings on the pipes was observed.

Site 1 – Corner of Marion and Hill Streets

The conduit was running water into the pit from both ends. The sump pump was operating and the pipes were dry. There was no evidence that the pipes had been under water over the previous year. The coating was in like-new condition except for rust that had dripped from overhead structural members. The areas on each pipe where the fiberglass laminate had been applied were in like-new condition, but there were no obvious benefits from the installation of the laminate. The pipes were hot to the touch but an inspector could touch the upper part 30 seconds without discomfort. The lower pipe could be held without discomfort. The test panels were retrieved for examination. There were no apparent changes other than the dirt accumulated from exposure.

Site 2 – Corner of Scales and Hood Streets

The conduit was dripping water into the pit from both ends. It had developed additional rust in the areas of the holes and green moss had again begun to grow. The area where the pipes were not blasted due to concern about perforation had been coated, but some of the remaining scale was loosening. Spots of pinpoint rust were forming in the area. The sump pump was operating and the pipes were dry, but a waterline indicated the test panels as well as the bottom half the lower pipe had been under water at one time. The coating was in like-new condition except for the rust that had dripped from overhead structural members. The few blisters that had formed at the time of application had not changed in appearance or size. The area on each pipe where the fiberglass laminate had been applied were in like-new condition, but there were no obvious benefits from the installation of the laminate. Coating thickness in this area was apparently greater, and both the upper and lower pipes could be held with no discomfort. The test panels were retrieved for examination. There were no apparent changes other than the dirt accumulated from exposure.

Site 3 – Sumter Street behind Building 2179

The conduit was in good condition but there was about 5 in. of water in the pit. This pit does not have electric service or a working sump pump. There was no evidence that the pipes had been under water over the past year. The coating was in like-new condition except for rust that had dripped from overhead structural members. There did appear to be a greater amount of rust in the flanges and on a few bolt thread areas. This amount of rust was minor but did appear to be greater than that seen in similar areas at the other Fort Jackson sites. The difference may be that the primer used at site 3 did not contain zinc or that it did not flow into the tight areas as well as the other two primers. The areas on each pipe where the fiberglass laminate had been applied were in like-new condition, but there were no obvious benefits of the installation of the laminate. The top pipe was so hot it could be touched only for a short time before causing a burn. The lower pipe could be held without any discomfort, however. The test panels were retrieved for examination. There were no apparent changes other than the dirt accumulated from the exposure.

Test panel evaluation

Figure 1 shows all three sets of test panels, and two control sets, after 12 months of exposure. Details about each panel and more photos are presented in Appendix B. In brief, however, it was determined that little to no coating degradation had occurred during the period of exposure. Some staining of the coating was observed in the site 2 specimens, but the coating integrity was unaffected.

Figure 1. Samples showing test panel results after 12 months of exposure in three separate pits. The vertical columns, left to right, are factory varnish, blasted, system 1 (epoxy primer), system #2 (MC urethane primer), and system 3 (silicone primer).

4 Metrics

The following metrics were applied to assess the results of this demonstration.

Coating performance was assessed for chalking, flaking, and rusting with reference to ASTM standards D622, D610, D772. The manufacturer's recommendations for application were followed.

A number of factors were quantified to provide valid baseline cases either before or without the application of the coating system. Here, weight loss coupons (called *test panels* throughout this report) were used to determine the corrosion rate within the environment. In order to allow for periodic sampling, multiple coupons were used. Three cases were covered:

1. uncoated pipe
2. any applicable existing coating (typically minimal to none)
3. the same coating system applied to the manhole piping as a control.

The temperature and relative humidity were monitored to quantify the modification of the environment and the resulting effect on corrosion.

Because the expected benefit of this technology will be realized over the long term, a full data set for quantifying the return on investment will not be available for years. However, relative frequency of leak repair, repair and maintenance costs, excessive heat loss, and overall system condition were monitored and compared with historical trends and experience, both at Fort Jackson and for similar heat distribution systems around the country.^{1, 2}

¹ Marsh, Charles P., Nicholas M. Demetroulis, and James V. Carnahan. July 1996. *Investigation of Pre-approved Underground Heat Distribution Systems*, USACERL Technical Report TR-96/77. Champaign, IL: U.S. Army Construction Engineering Research Laboratory.

² Marsh, Charles P., Brian A. Temple, and Angela Kim. July 2001. *Condition Prediction Model and Component Interaction Fault Tree for Heat Distribution Systems*, ERDC/CERL TR-01-35. Champaign, IL: U.S. Army Engineer Research and Development Center – Construction Engineering Research Laboratory.

5 Economic Summary

Projected return on investment

The projected return on investment (ROI) for this project was determined to be 58. It should be noted that, strictly speaking, a return on investment is applicable specifically to cases in which an investment produces a profit or financial return. Because the economic benefit of this technology is cost savings rather than a hard financial return, it is technically more correct to express the benefit as a savings-to-investment ratio (SIR). The value of the benefit is the same, so the terms are interchangeable, but ROI is used here for discussion in the context of the Army CPC Program.

Assumptions

The full economic analysis is presented in Appendix C. The findings of the analysis were that the ceramic coating system provides a net savings of \$63,366 per manhole over a 20-year life cycle, and an ROI of 58. The analysis also determined the payback period for the initial investment to be 16.2 years.

Not included in this analysis are the energy savings of providing a partial insulating capability where, typically, bare pipes are found after 7 – 10 years of service. Occasional manhole flooding and general wear and tear tends to degrade the insulation. The ceramics-based insulating coating provides some insulation value even when wet. Also not covered in the economic analysis is the improved worker safety factor, where the possibility of burns is virtually eliminated by application of a coating that is only warm to the touch while the HDS is operating. An additional value of the worker safety benefit is that maintenance is more likely to be performed on schedule where the danger of burns is reduced, thus promoting the long-term reliability and efficiency of the system in the support of mission objectives.

6 Recommendation

It is recommended that the managers of U.S. military installations fully consider utilizing the subject insulating ceramic coating system on various HDS elements in manholes to prevent corrosion, extend infrastructure service life, and avoid potentially costly leaks and component replacement.

It also is recommended that a partial amount of conventional insulation material be used in conjunction with the ceramic coating system. Doing so while also applying the insulating ceramic coating will modify the internal manhole environment toward conditions that will greatly reduce corrosive degradation while restoring the full thermal insulation capacity to an as-built or “like-new” condition.

7 Implementation

It is recommended that this technology be adopted widely and implemented by inclusion in the applicable Unified Facilities Guide Specifications (UFGS) and Technical Manuals (TM). In particular, UFGS-33 60 01, *Valves, Piping, and Equipment in Valve Manholes* (July 2006) would be the primary document in which to codify this change. In addition, UFGS-33 61 13, *Pre-Engineered Underground Heat Distribution System* (April 2006) may require modification if the conduit end plates are to be coated. Inclusion in the original design of new systems would also be aided by incorporating this technology in Army TM 5-810-17, *Heating and Cooling Distribution*.

8 Conclusion

This project demonstrated the benefits of an innovative ceramics-based insulating coating system in protecting high-temperature HDS pipes located in manholes. Periodic field inspections and examination of exposed test panels were performed at intervals of 4, 8, and 12 months. In addition temperature measurements were used to estimate heat loss.

A third-party economic analysis estimated that the ROI for this technology would be about 58, with an initial payback period of 16.2 years. These results however are somewhat skewed in that the base comparison case addressed insulated pipes whereas the piping insulation in manholes is often found to be significantly damaged or missing. The addition of some portion of the original intended insulation thickness could help to make up for the design insulating capacity not provided by the coating.

In addition to the extra corrosion protection provided by this coating system, in part through mitigation of the corrosive conditions in the manhole environment, the improvement in thermal performance should yield good returns on an ongoing basis, especially with expected long-term increases in energy costs. Also, system reliability enhancements provided by this technology offer a benefit in terms of improved mission support and readiness.

Appendix A: Project Management Plan (PMP)

TRI-SERVICE PROGRAM
ARMY FACILITIES

CORROSION PREVENTION AND CONTROL PROJECT PLAN

Innovative Corrosion Resistant Materials/Indicator Coatings for High
Temp/Steam Piping at Ft. Jackson

Project No.: IMA2

November 2004

(as modified from 13 July 2004 version)

Submitted By:

Charles Marsh

U. S. Army Engineer Research & Development Center (ERDC)
Construction Engineering Research Laboratory (CERL)

Comm: 217-373-6764

(Project Number to be assigned by OSD when approved)

1. STATEMENT OF NEED

PROBLEM STATEMENT:

Ft. Jackson, IMA and ACSIM have identified heat distribution systems as a critical part of the infrastructure needed to support the installation mission. During their normal service life piping in heat distribution system (HDS) manholes throughout the Army and the Tri-Services routinely experience an environment that is both hot and humid. This results in an ongoing and severely corrosive environment to which bare and often un-insulated steel piping is exposed.¹ Add to this multiple occurrences of leaking valves, pinhole leaks in condensate lines, ground water ingress, and occasional flooding and this accelerated degradation often results in the piping quickly reaching half of the useful life cycle (typically 25 years²) within five to eight years. In addition, flooded manholes are at a near optimal temperature for nucleate boiling and can result in excessive and additional heat loss. For example a boiling manhole is estimated to lose from \$50,000 to \$125,000 worth of heat per year if not repaired³ while also prematurely degrading via corrosion the critical internal piping connections and appurtenances. Boiling manholes can easily go uncorrected for six or more years, and their eventual replacement repair, due to their shortened useful life, will also be expensive. Given that the manholes are both necessary and required, but also represent a reliability weakness, a means to better protect the manhole piping is needed. Even in normal operation the warm-to-hot and often humid manhole environment is inherently prone to accelerated corrosive degradation.

IMPACT STATEMENT:

Implementation of this project will result in avoided adverse impact to mission critical basic and/or proficiency training through loss of building space heating and hot water supply. Similar impacts to other base operations will also be avoided. Other benefits will include significant reduction in operational and replacement expenses⁴ allowing more budgetary lee way for mission support, as well as improved system reliability and extended useful service life. Another plus is that maintenance worker safety will also be improved through less chance of burns, water hammer, catastrophic valve failure, and lack-of-oxygen confined space fatalities. More specifically, the expected benefits of innovative corrosion resistant coatings are to protect internal manhole piping connections (i.e., hot water/steam supply and return line take offs from the main feeder trunk line) and valves from corrosion in a typically highly corrosive environment. An additional advantage of the intended innovative coating is to lower the hot pipe surface temperature

¹ "Causes and Control of Corrosion in Buried-Conduit Heat Distribution Systems", USACERL Technical Report M-91/08 (July 1991), James R. Myers, Ellen G. Segan, Charles P. Marsh, Vincent F. Hock.

² In addition, for long lived systems mandated by 10 CFR 436.14(d)(2) not to exceed 25 years

³ "Boiling Manhole Heat-Loss Calculations", USACERL Technical Report 98/62 (June 1998), Charles Marsh and Terrill Loughton. Note: these calculations use an old Army "Red Book" [FY94, Vol I] cost of energy value of \$6.79 per MBtu.

⁴ Replacement costs typically run \$300 - \$800/ft. (1 mile = \$1.6M and up). A relatively recent Army Utilities Modernization program was funded at 5 x \$60M/yr = \$300M

and provide burn protection to the maintenance worker. This also means that a modest amount of effective insulation is added in a small added thickness. Since heat distribution systems are in fact collections of interacting components⁵ the overall system condition will also be maintained. Taken all together these advantages result in a longer, energy efficient service life, lower life cycle cost operating costs, increases the likelihood of maintenance procedures being performed and an extended time between overall system replacement.

2. PROPOSED SOLUTION

TECHNICAL DESCRIPTION:

This project will use a liquid ceramic coating to coat newly constructed, bare, manhole piping in heat distribution systems (e.g., Utility Modernization jobs). This class of coatings has over 10 years of experience in industrial settings but is not currently used within the Army for HDS manhole piping. With as little as 180 mils a 350F pipe can be rendered non-painful for contact with bare skin. However, mainly the overall environment will be rendered significantly less corrosive while directly protecting the piping. In addition, depending on the specific application situation, an indicator coating may also be applied. This will consist of either a distinctively colored intermediate layer to easily show by visual inspection that it's time for recoating, or, a thermal indicator coating which shows a color change above specific graded temperature. Either of these indicator coatings will yield an easily perceived "test result" showing the current status of the manhole piping and prompt appropriate maintenance procedures as needed.

Technology Maturity:

This technology is mature and so low risk, with many years of proven experience. As one recent example a steam generation and distribution company in Detroit, MI is currently in the process of coating piping (including all appurtenances such as valves, fittings, and connectors) in their 900 manholes with 60 mils of this type of coating. One beneficial effect has been to decrease the ambient working condition temperatures which allow crews to work longer and without excessive ventilation.

⁵ "Condition Prediction Model and Component Interaction Fault Tree for Heat Distribution Systems", Marsh, Temple, Kim, ERDC/CERL TR-01-35 (July 2001).

Figure 1: Commercial valve and piping coated with a liquid ceramic coating.

RISK ANALYSIS:

This is a **low risk** project in that the coating products are commercially available from multiple manufacturers. Ongoing, widespread industry experience over at least the last 10 years strongly indicates that successful application and long term performance should be expected. In addition, based on past working relationships at the first implementation site, Ft. Jackson, SC, they are very receptive to heat distribution system improvements. In fact, Ft. Jackson is one of the sites of a multi-year FEAP/FTAT project comparing concrete shallow trench to direct buried heat distribution systems in the 1990s. This prior work resulted in significant improvements in the applicable guide specifications, TM 5-810-17 and AR 420-49. This project will be implemented at Ft. Jackson without the need of a phased approach.

EXPECTED DELIVERABLES AND RESULTS/OUTCOMES:

Depending upon manhole size and the associated internal piping surface area, from 25 to 40 manholes will be upgraded with the application of liquid ceramic coatings. As needed an appropriate indicator coating will also be included. In addition, supplied to the installation will be draft contract language and specifications (e.g., surface preparation, product acceptance requirements, safety procedures, etc.) for use on additional applications. The expected outcome is that there will be less operational distribution heat loss, significantly less corrosion will occur on upgraded manhole piping and a more reliable and longer service heat distribution system should result. Follow up coating assessments will be used to further assure and document expected performance.

PROGRAM MANAGEMENT: The Project Manager will be: Dr. Charles Marsh (ERDC-CERL Senior Researcher and Materials Engineer). The Associate Project Manager will be: Mr. David Kessler. The stakeholders will be Mr. Steve Jackson (IMA-SERO), and Mr. Tom Tehada (USN) and Ms. Nancy Coleal (USAF). Customers are: Mr. George Dibb, Department of Logistics and Engineering, Ft. Jackson. The approach will include contacting mechanisms such as Indefinite Delivery Indefinite Quantity (IDIQ) Contract. An IDIQ Task Order and/or a technically qualified 8A contract for this project are expected to be awarded by 1 month after receipt of funds. Direct Cite funds will be used for contracts for implementing innovative manhole piping coatings at Fort Jackson.

3. COST/BENEFITS ANALYSIS

a. Funding (\$K):

Funding Source	OSD	IMA
Labor	N/A	170
Materials	N/A	90
Travel	N/A	18
Report	N/A	15
Air Force/Navy Participation	N/A	---
SUBTOTAL	N/A	293
Overhead	N/A	67
TOTAL (\$K)	N/A	360

Development Project Budget

The \$360K budget is realistic and adequate for the scope of the project. ERDC-CERL has an historic and ongoing familiarity with the Ft. Jackson heat distribution system. This association dates back to at least the 1980s heat distribution system upgrade and later associated FTAT (later FEAP) program and carries through to a recent assessment performed for the Utilities Modernization program.

b. Return-On-Investment Computation

Using the required OMB spreadsheet, and in accordance with OMB Circular A-94, a return-on-investment (ROI) of 15.74 was calculated (see Appendix 1 below along with installation specific supporting notes and cited references). The associated savings were \$5.7M. This ROI value is based on current best practices, as well as projected maintenance and rehabilitation practices and costs. In addition, conservative values for average energy costs and mostly labor based expenses for leak repair have been chosen since they are well documented.

c. Mission Criticality

The operational benefits of implementation of this technology for these mission critical systems are enhanced thermal efficiency, improved life cycle costs, lower ongoing operating costs, improved worker safety and increased system wide reliability for heat distribution systems.

4. SCHEDULE

MILESTONE CHART

EVENT	TIME (months after receipt of funds)
Award Contract	1
Site Visit to Select Manholes	2
Select Liquid Ceramic and Indicator Coating Products	2
Begin On Site Coating Application	3
Complete Coating Application	5
Complete Draft Contract Language and Procurement Documents for Installation	6
Perform Follow Up Assessment	10
Complete Documentation (includes Final Report, Procurement Specification, Ad Fliers)	12
Complete ROI Validation	12

- a. Note: If project is approved, *bi-monthly status reports will be submitted* (i.e. starting the first week of the second month after contract award and every two months thereafter until final report is completed). This report will be submitted to the DoD CPC Policy & Oversight office. Report will include project number, progress summary (and/or any issues), performance goals and metrics and upcoming events.
- b. Examples of performance goals and metrics: include achieving specific milestones, showing positive trend toward achieving the forecasted ROI, reaching specific performance quality levels, meeting test and evaluation parameters, and/or successfully demonstrating a new system prototype.

5. IMPLEMENTATION

a. **Transition approach:** Unified Facilities Guide Specifications (UFGS), Engineering Instructions (EI), Technical Instructions (TI), and Technical Manuals (TM), including updates, along with a final report describing the details of the project, will be developed and posted to the OSD Corrosion Exchange website under "Spec & Standards" and "Facilities SIG." In addition, the guidance will be ERDC-CERL Corrosion Prevention and Control Program (CPCP) website. Coordination with potential users will be an essential part of the transition of the technology. It is the intent of the Project Management Plan (PMP) to implement this corrosion prevention and control technology at multiple regions and installations over the next six years, according to the schedule shown below. The UFGS, EIs, TIs, and TMs, including updates to existing guidance documents,

developed for Army-wide implementation during the FY05 project, will be utilized to facilitate the planned implementation over the next six years.

FY	OSD Funds	HQ-IMA Matching	Planned Regions	Planned Installations
06	\$480K	\$480K	SERO	Ft. Bragg, Redstone Arsenal
07	\$480K	\$480K	NERO	West Point, Ft. Lee
08	\$480K	\$480K	NERO, NWRO	Ft. Riley, Ft. McCoy
09	\$480K	\$480K	NWRO	Ft. Lewis, Ft. Leonard Wood
10	\$480K	\$480K	PARO	Ft. Richardson, Ft. Shafter
11	\$480K	\$480K	NERO	APG, Ft. Belvoir

b. Potential ROI validation. ROI will be validated by comparison of coated manhole piping with otherwise identical but un-coated manhole piping. The calculated ROI for this project, which is based on current best practices, projected maintenance and rehabilitation cost, has the potential to increase over the multiple year implementation due to the reduction in down time, which will result in increased indirect savings. In subsequent years, the extension of useful and energy efficient service life of the heat distribution system, along with any applicable indirect savings, will be used to further refine and validate the ROI calculation. Third party validation will be used to document the ROI savings performance of this project. This validation work will be performed by an impartial and technically qualified individual such as a NACE-certified Corrosion Expert or by an expert in heat transfer such as Mr. Bob O'Brien of Washington State University.

c. Final Report: A final report will be written 60 days after the project is completed. The report will reflect the project plan format as implemented and will include lessons learned.

Projected Benefits

Based on extensive industry experience over many years this coating system should reduce corrosion in what typically can be an adverse and high corrosion environment (i.e., high temperature and high humidity). Additional benefits of increased energy efficiency and enhanced worker safety are also expected. Overall this project will help to prevent heat distribution system wide premature failure and excessive heat loss over and above the designed value. A more reliable supply of space heating and hot water, which often is also used in industrial process applications, will result in a positive impact to mission requirements and continued operational readiness at Ft. Jackson.

Management Support

This project is supported by the Ft. Jackson DPW Office as well as the IMA-SERO Region (see coordination sheet signatures). In addition, the Army (HQ-IMA and HQ-ACSIM) have reviewed this project and provided matching funds for FY05. See associated Memorandum from ACSIM Director for Facilities and Housing.

6. COORDINATION SHEET

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager	(see attached)	
ERDC/CERL Branch Chief	(see attached)	
Installation DPW POC	(see attached)	
IMA Region	(see attached)	
HQ IMA	(see attached)	
HQ ACSIM	(see attached)	
HQ AMC	Hilton Mills approved: signature is being sent under separate cover.	
Tri-Service Facilities WIPT Chair	(see attached)	

6. COORDINATION SHEET

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
WIPT Chair	_____	_____
ACSIM	_____	_____
HQ IMA	_____	_____
IMA Region	_____	_____
Installation DPW	<i>B. Mills</i>	<i>5/10/2004</i>
Installation POC	_____	_____
ERDC/CERL Branch Chief	_____	_____
Project Manager	_____	_____
Service CPC IPT Representative	_____	_____

6. COORDINATION SHEET

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager	_____	_____
ERDC/CERL Branch Chief	_____	_____
Installation DPW POC	_____	_____
Installation Environmental POC	_____	_____
IMA Region (SE)		7/1/2004
HQ IMA	_____	_____
HQ ACSIM	_____	_____
HQ AMC	_____	_____
Tri Service Facilities WIPT Chair	_____	_____

This is a TriService Project. Funds have been requested for Air Force and Navy representatives to participate in the evaluation of technology implementation.

6. COORDINATION SHEET

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager	_____	_____
ERDC/CERL Branch Chief	_____	_____
Installation DPW POC	_____	_____
Installation Environmental POC	_____	_____
IMA Region		7/12/04
HQ IMA	_____	_____
HQ ACSIM	_____	_____
HQ AMC	_____	_____
Tri Service Facilities WIPT Chair	_____	_____

This is a TriService Project. Funds have been requested for Air Force and Navy representatives to participate in the evaluation of technology implementation.

6. COORDINATION SHEET

only original

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager		
ERDC/CERL Branch Chief	Mate Floris	7/1/04
Installation DPW POC	RTDm.1.1a	5/20/2004
IMA Region	Steve Jackson	01 JUNE 2004
HQ IMA	Paula	6/22/04
HQ ACSIM	Steve Russell	18 June 04
HQ AMC		
Tri-Service Facilities WIPT Chair	Thomas Chade	24 June 2004

6. COORDINATION SHEET

only original

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager		
ERDC/CERL Branch Chief	Mate Floris	7/1/04
Installation DPW POC	RTDm.1.1a	5/20/2004
IMA Region	Steve Jackson	01 JUNE 2004
HQ IMA	Paula	6/22/04
HQ ACSIM	Steve Russell	18 June 04
HQ AMC		
Tri-Service Facilities WIPT Chair	Thomas Chade	24 June 2004

6. COORDINATION SHEET

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager	<i>Charles Marsh</i>	8 JUL 04
ERDC/CERL Branch Chief		
Installation DPW POC	<i>A. Smith</i>	5/20/2004
IMA Region	<i>Steve Johnson</i>	01 JUNE 2004
HQ IMA	<i>David</i>	6/22/04
HQ ACSIM	<i>David Russell</i>	18 June 04
HQ AMC		
Tri-Service Facilities WIPT Chair	<i>Thomas Echick</i>	24 June 2004

only original

6. COORDINATION SHEET

<u>ORGANIZATION</u>	<u>SIGNATURE</u>	<u>DATE</u>
Project Manager	_____	_____
ERDC/CERL Branch Chief	_____	_____
Installation DPW POC	_____	_____
Installation Environmental POC	_____	_____
IMA Region	_____	_____
HQ IMA	_____	_____
HQ ACSIM	<i>David Russell</i>	18 June 04
HQ AMC	_____	_____
Tri Service Facilities WIPT Chair	<i>Thomas Echick</i>	24 June 2004

This is a TriService Project. Funds have been requested for Air Force and Navy representatives to participate in the evaluation of technology implementation.

7. APPENDICES

Appendix 1: Potential ROI Calculations based on OMB Circular A-94

Return on Investment Calculation

Investment Required		360,000
Return on Investment Ratio	15.74	Percent 1574%
Net Present Value of Costs and Benefits/Savings	14,047	5,680,170 5,666,123

A Future Year	B Baseline Costs	C Baseline Benefits/Savings	D New System Costs	E New System Benefits/Savings	F Present Value of Costs	G Present Value of Savings	H Total Present Value
1	500		2,000	62,420	1,860	58,805	56,938
2	500		2,000	62,420	1,747	54,954	53,208
3	500		2,000	117,850	1,633	96,606	94,977
4	500		2,000	117,850	1,526	90,286	88,763
5	500		2,000	122,070	1,426	87,392	85,966
6	500		2,000	126,300	1,333	84,487	83,154
7	500		2,000	173,280	1,245	108,213	106,967
8	500		2,000	169,060	1,164	98,684	97,520
9	500		2,000	232,940	1,088	126,968	125,880
10	9,300,000		2,000	288,370	1,017	4,873,768	4,872,752
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							

Supporting calculations for Avoided Costs (Column E):

COL. E: AVOIDED COSTS

NOTE: HDS SYSTEM REPLACEMENT (yr 11 and after)

System length (ft): 31000

YEAR	energy cost (\$/Mbtu)	# man holes boiling	excess MH heat loss (Mbtu/yr)	excess MH energy loss per year (K\$/MH)	No of leaks	Leak repair costs*	Total leak repair costs (K\$)	Manhours for yearly manhole inspection	No. man holes	\$ per man hour	annual inspection costs (K\$)	TOTAL COL. E
1	6.79	1	7542.00	51.21	2	4.22	8.45	2	44	20	1.76	61.42
2	6.79	1	7542.00	51.21	2	4.22	8.45	2	44	20	1.76	61.42
3	6.79	2	7542.00	102.42	3	4.22	12.67	2	44	20	1.76	116.85
4	6.79	2	7542.00	102.42	3	4.22	12.67	2	44	20	1.76	116.85
5	6.79	2	7542.00	102.42	4	4.22	16.89	2	44	20	1.76	121.07
6	6.79	2	7542.00	102.42	5	4.22	21.12	2	44	20	1.76	125.30
7	6.79	3	7542.00	153.63	4	4.22	16.89	2	44	20	1.76	172.28
8	6.79	3	7542.00	153.63	3	4.22	12.67	2	44	20	1.76	168.06
9	6.79	4	7542.00	204.84	6	4.22	25.34	2	44	20	1.76	231.94
10	6.79	5	7542.00	256.05	7	4.22	29.56	2	44	20	1.76	287.37

At the end of year 10 the system is replaced. This results in an additional cost of 31000 X \$300/ft = \$9,300 K. Thereafter the installation experiences a significant reduction in: normal distribution heat loss, # boiling manholes, # leaks

The ongoing expense of implementing this technology (Column D) consist only of inspection calculated as 2 man-hours per manhole per year, at \$20/man-hour for 44 manholes = \$1,760. In the ROI spreadsheet this has been rounded up to \$2,000 to include incidentals and any recoating touch-ups needed. In addition to the avoided costs detailed above, the over-and-above savings of this technology (included in Column E) are conservatively estimated at \$1K/yr for not having to instead run space heaters and/or rent portable boilers, possibly for multiple buildings, to provide alternate sources of space heating and/or domestic hot water in the event of a service interruption.

The estimated number of leaks is meant to be representative and is here chosen to be generally increasing toward the end of the useful life of a heat distribution system while still retaining some variability.

No attempt has been made to estimate impacts on productivity, morale, or training hours. As well, energy costs are here assumed to be constant with a well documented and conservative value being chosen. Alternatively, if a more complete analysis were to be done using the latest energy escalation factors (projected rising energy costs over and above that of inflation/discount rate) for the southeast region the expected result would be to slightly increase the current ROI estimate.

Supporting Notes for ROI Calculation for Ft. Jackson HDS

Ft. Jackson has at least 31,000-ft of direct buried (DB) heat distribution system (HDS) piping⁶. These were installed in the 1986-1988 time frame as follows:

- Phase I (2200 block): 13,500-ft DB, completed 29 AUG 86
- Phase II (3200 block): 6,500-ft DB, completed 27 JAN 88
- Phase III (4200 block): 11,000-ft DB, completed 26 FEB 87

The typical approximate replacement cost, in 2004 dollars, is \$300 / ft. Without the application of this corrosion prevention technology a replacement is projected to be needed in 10 years time. In current dollars this would be a total of \$9.3M.

Assuming a conservative average of 500-ft. of trunk line and 200-ft. of "take off" to feed one or more buildings per manhole, this implies a total of 44 manholes. As existing, original system degrades some small but significant number of these manholes will flood and proceed to boil. As described in detail in an applicable Technical Report⁷ each of these can lose \$51K/yr. It is worth noting that this value is derived using an energy cost from FY94 of just \$6.79 per MBtu. If recent history is any guide a more representative value is likely to increase. In the calculation of this ROI any ongoing elevated heat loss, over and above acceptable designed transmission losses, of conduit sections between manholes is not accounted for here. However, a heat distribution system is a complicated collection of interacting components where the effects of a local failure can cause adverse effects throughout the system. To better understand these interactions please see the referenced ERDC/CERL Technical Report⁸. The value used for leak repair is a documented value⁹ from Ft. Jackson and is in 1991 dollars. The appropriate section of the conference paper is reproduced below.

APPENDIX B: COSTS OF JAN 1991 CONDUIT LEAK IN FT. JACKSON

The leak occurred in the high temperature hot water prefabricated buried conduit line at the 5400 block on 1 Jan 1991. The repair crew began work at 7:00 am and did not stop until 3:30 am early the next morning. In order to find the leak 13 holes (5 in asphalt, 7 in soil) were dug owing to a long pipe run from the central energy plant number 2 to the manhole serving the first building.

Location and repair:

three workmen at 22 hours	\$1,128
one workman at 10 hours.....	296
one supervisor at 21 hours.....	495
three trucks and two backhoes.....	224
patch hole in conduit.....	300

Patch asphalt and fill:

asphalt material.....	\$ 400
labor.....	160

Replace curb and sidewalk:

concrete.....	\$ 120
labor.....	900

Landscape (fill and cover).....

	\$ 200
--	--------

Total \$4,223

⁶ Letter Report by NMD & Associates dated 17 November, 1995

⁷ "Boiling Manhole Heat-Loss Calculations", Marsh, Loughton, USACERL Technical Report 98/62 (June 1998).

⁸ "Condition Prediction Model and Component Interaction Fault Tree for Heat Distribution Systems", Marsh, Temple, Kim, ERDC/CERL TR-01-35 (July 2001).

⁹ Charles Marsh, "Lessons Learned to Date From the Ft. Jackson, SC FEAP Heat Distribution Systems Demonstration Project", Corps of Engineers Electrical and Mechanical Training Conference, Dallas, TX, July 1992.

Appendix B: Test Panel Results

Test panels using different primers were placed in three separate pits. Figures B1 – B3 show the result of exposure for 4, 8, and 12 months. Table B1 summarizes the coating details, location and exposure time for all test samples used.

Figure B1. Samples showing results after 4 months of exposure in three separate pits. The vertical columns, left to right, are factory varnish, blasted, System #1 (Epoxy primer), System #2 (MC Urethane primer), and, System #3 (Silicone primer).

Figure B2. Samples showing results after 8 months of exposure in three separate pits. The vertical columns, left to right, are factory varnish, blasted, System #1 (Epoxy primer), System #2 (MC Urethane primer), and, System #3 (Silicone primer).

Figure B3. Samples showing results after 12 months of exposure in three separate pits. The vertical columns, left to right, are factory varnish, blasted, System #1 (Epoxy primer), System #2 (MC Urethane primer), and, System #3 (Silicone primer).

Table B1. Test panel locations, coating system, and duration of exposure.

Panel #	Primer	Midcoat	Topcoat (total system)	Location	Exposure time (Months)
	20-Jul-05	21-Jul-05	5-Aug-05		
0	Factory Varnish			1	12
1	Factory Varnish			1	8
2	Factory Varnish			1	4
3	Factory Varnish			2	4
4	Factory Varnish			2	8
5	Factory Varnish			2	12
6	Factory Varnish			3	8
7	Factory Varnish			3	12
8	Factory Varnish			3	4
9	Factory Varnish			Not in test	
10	Bare			1	12
11	Bare			1	8
12	Bare			1	4
13	Bare			2	12
14	Bare			2	8
15	Bare			2	4
16	Bare			3	8
17	Bare			3	4
18	Bare			3	12
19	Bare			Not in test	
	MIL-DTL 24441(F159) 2-3 mils				
20		20	36-55	1	12
21		22	47-51	1	8
22		23	41-61	1	4
23		22	45-51	2	12
24		20	43-57	2	8
25		19	41-58	2	4
26		27	46-73	Not in test	
27		25	39-54	3	8
28		18	44-53	3	12
29		24	37-45	3	4
	MCzinc (2-3) mils				
30		18	33-61	Not in test	
31		19	35-41	1	12
32		18	38-47	1	8

Panel #	Primer	Midcoat	Topcoat (total system)	Location	Exposure time (Months)
33		22	52-61	1	4
34		20	43-46	2	12
35		20	38-53	2	8
36		22	40-58	2	4
37		20	42-57	3	8
38		22	39-51	3	12
39		22	39-67	3	4
	Hi Temp (2-3 mils)				
40		20	37-49	Not in test	
41		20	50-68	1	12
42		20	42-55	1	8
43		21	38-59	1	4
44		18	47-64	2	12
45		19	44-57	2	8
46		19	44-55	2	4
47		22	44-55	3	8
48		21	38-55	3	12
49		22	50-54	3	4

The test panels were prepared as indicated below:

Panels Number 0-9

Rear blast & paint only

MIL-DTL-24441 system

(3 mil each)

Front – no-blast no-paint

Panels Number 10–19

Blast all surfaces

Rear paint

MIL-DTL-24441 system

(3 mil each)

Front no-paint

Panels Number 20–29

Blast all surfaces

Paint rear

MIL-DTL 24441 system

(3 mil each)

Paint front with MIL-DTL 24441(F159) 2-3 mils

Front second coat Ceramic 45 mils

Panels Number 30–39

Blast all surfaces

Paint rear

MIL-DTL 24441 system

(3 mil each)

Paint front with MCzinc (2-3) mils

Front second coat Ceramic 45 mils

Panels Number 40–49

Blast all surfaces

Paint rear

MIL-DTL 24441 system

(3 mil each)

Paint front with Hi Temp (2-3 mils)

Front second coat Ceramic 45 mils

Appendix C: Third-Party ROI Report

Economic Analysis of the Heat Distribution System Ceramic Paint Coating

Submitted to
US Army Engineer Research and Development Center
US Army Construction Engineering Research Laboratory
ATTN: Dr. Charles Marsh
2902 Newmark Drive
Champaign, Illinois 61822-1076

By
The PERTAN Group
44 Main Street, Suite 403
Champaign, Illinois 61820-3636
May 12, 2006
Final Report

Executive Summary

Underground Heat Distribution Systems are critical to support the installation mission at many US Army garrisons. Current maintenance and repair practices reduce their service life considerably. This analysis compares the costs and benefits of an alternative coating method with those of the status quo practice. The alternative maintenance methodology contemplates coating the carrier pipes inside the manholes with a coat of corrosion protection primer paint and two coats of ceramic based paint. The economic analysis found that the ceramic coating alternative has a net saving of \$63,366 per manhole over a 20-year life cycle and a Savings to Investment Ratio of 58. However, the analysis also found that it takes 16 years to recover the initial investment, and that the energy losses of the ceramic coating alternative are considerably higher than those of the status quo alternative. Finally, this report recommends adding insulation to the ceramic based paint to save energy.

Introduction

Background

Many U.S. Army installations rely upon central district Heat Distribution Systems (HDSs) to provide heating and hot water to their facilities. Fort Jackson has identified HDS as a critical part of the infrastructure to support the installation mission. HDSs are large complex systems made up of numerous components highly interdependent on one another. The deterioration of one component affects the performance and deterioration rate of other nearby components.

Manholes in a HDS house many of the critical components and also connect the different pipe sections of the system. The environment inside the manholes is often hot and humid and hence conducive to corrosion. Carrier pipes inside manholes are usually wrapped with insulation to prevent heat losses and protect service personnel entering the manhole. Water enters the manholes from leaking valves, rain, and ground water ingress. The water then gets trapped into the insulation and in between the insulation and the pipe. This condition makes the corrosive environment around the carrier pipe more severe and speeds the deterioration of the carrier pipe.

The corrosion of the carrier pipe in the manholes has a ripple effect though the other components in the same manhole and the connecting pipes¹. Protecting the carrier pipe inside the manholes against corrosion extends the service life of the entire HDS considerably. It is then desirable to have a cost effective coating alternative able to protect the carrier pipes against corrosion while keeping the outside temperature of the pipes low enough to protect service personnel entering the manhole.

Objective

The objective of this analysis is to provide quantitative documentation of economic Return on Investment (ROI) performance of the heat distribution system coating system that will be installed at Fort Jackson, SC.

Approach

This analysis follows the seven-step process outlined in the Department of the Army Economic Analysis (EA) Manual and recommended by DODI 7041.3. The process is depicted in Figure C1 below. These seven steps are divided into four major categories: Study Formulation, Determine Costs and Benefits, Perform Analysis, and Report Results.

Figure C1. Economic analysis process.

¹ Underground Heat Distribution Systems; Robert O. Couch, Ricwil Piping Systems; 1993 Federal Section Conference; IDCA; May 20-21, 1993; Arlington, VA;.

Study Formulation

The first three steps of the Economic Analysis process involve the formulation of the study. They are: Definition of Objectives, Formulation of Assumptions, and Identification of Alternatives.

Determine Costs and Benefits

This step of the Economic Analysis (EA) process is the determination and estimation of the different costs and benefits of each alternative. It involves the selection of the different cost elements involved and the gathering of the corresponding values.

Perform Analysis

The next two steps of the AIS EA Handbook involve (1) the evaluation and comparison of the different alternatives according to the costs and benefits obtained before and (2) performance of a sensitivity analysis.

Report Results

The final step of the EA process is the reporting of the results. This step involves documenting all estimates and explaining recommendation(s).

Scope

This study is an economic analysis, not a budget analysis. Economic analysis and budget analysis are different processes. While an economic analysis is used for determining the most cost-effective alternative that meets an organization's requirement, a budget analysis provides an organization with the total cost impact of an alternative. The data presented in an economic analysis may or may not be useful in a future budget process. Some costs are omitted from the economic analysis because they are wash costs (a cost that is identical for all alternatives). Also, some costs included in the economic analysis may refer to several organizations, making it difficult to use them in the budgeting process.

Mode of Technology Transfer

The recommendation of this report will be used to specify corrosion protection treatment in Heat Distribution Systems.

Study Formulation

Definition of Objectives

This is the first step of the EA and also the most important. A clear and concise objective will set the boundaries of the study and will define the goal to be accomplished in measurable terms. Clearly, an improperly stated objective will lead to an improper solution.

Problem

Carrier pipes in the manholes of HDS are routinely exposed to a corrosive environment of humidity and heat. That corrosive environment is exacerbated by leaking valves, ground water ingress, and occasional manhole flooding. Current corrosion protection systems aim to protect the conduit pipe. Moreover, current design/construction practices wrap insulation around the carrier pipes in the manhole to prevent heat losses and to protect maintenance personnel working in the manhole from high temperature pipes. However, after the manhole is flooded, insulation traps moisture around the carrier pipe and speeds up corrosion.

Project Objective

The objective of this project is to identify an alternative to the current practice of wrapping insulation around pipes. The alternative should be cost effective and provide a better corrosion protection without compromising safety.

Formulation of Assumptions

In order to perform an EA, several assumptions about future events need to be made. Following is the list of assumptions used in this analysis:

- The start year of the analysis is FY-2005.
- The lead-time (period extending from the start year to the completion of installation) is 1 year. At the end of the first year all 100% of the benefits are achieved.
- The period of analysis is 20 years.
- The real discount rate is 4%.
- Cost elements for each alternative are estimated using an average manhole. The average manhole is 10 ft by 10 ft and has two pipelines in it, supply and return. Inside the manhole there is a T in each line and a

Identification of Alternatives

Currently, underground direct buried drainable dryable steel conduit HDS are protected against corrosion by several means. The soil-side surface of the conduit pipe is protected by a special coating and/or cathodic protection. The interior side of the carrier pipe is protected by chemical water treatment performed continuously at the central plant. Corrosion in the annuli between the conduit pipe and the carrier pipe can be prevented by properly monitoring the moisture condition of this space through the drains and vents at the end plates inside the manholes. However, the sections of carrier-pipe inside the manholes are not well protected against corrosion. Those sections are wrapped with insulation and protected with an aluminum jacket. Moisture entering the manhole through the top gets trapped between the insulation and the outer side of the carrier pipe speeding up the corrosion process.

Current Method (Status Quo) Alternative

In this alternative, insulation is wrapped directly around the exterior side of the carrier pipe all through the section of pipe enclosed in the manhole. Current maintenance practices call for visual inspection of the insulation periodically and the substitution of the insulation when it is missing or highly deteriorated. However, this practice can not inspect the surface between the insulation and the pipe when the insulation is not missing even if it is saturated with moisture. Moreover, maintenance personnel shortages make the inspections unlikely and lack of maintenance funds make the insulation replacement prohibitive.

Corrosion Protection Primer-Ceramic Paint Combination (P-CP)

In this alternative, when the insulation is deteriorated, it is replaced by a ceramic paint instead of replacing it by a similar insulation. After removing the deteriorated insulation, the exterior side of the carrier pipe inside the manhole is first treated with a zinc based paint to protect against corrosion. Then, it is painted with a ceramic paint to insulate the pipes and protect workers entering the manhole from injuries due to high temperature pipes.

Cost and Benefits

Determining the costs and benefits associated with each alternative is the fourth step of an EA. This part of the analysis focuses on the collection and the comparison of the costs of implementing each alternative and the benefits associated with each course of action. Two issues worth considering before estimating costs and benefits are (1) relevance of the cost element and (2) level of accuracy of the estimate.

When comparing alternatives, not all cost elements are necessarily used in the analysis. The goal of the economic analysis is to only determine the most cost-effective alternative to the government that meets the organization's requirement. The outcome of the analysis is a ranking of the two alternatives. Only the differential costs between alternatives are considered in the analysis. Cost elements that do not affect the order of the ranking and are common to all alternatives are not considered here. In other words, costs that are identical for both alternatives (wash costs) are excluded from the evaluation and only the relative differences between alternatives are developed and compared.

The same rationale applies to the level of accuracy that is required for the estimates to be relevant. Many of the estimates used in this analysis are expert opinions and are not expected to be 100% accurate. To test the impact of the estimates' accuracy on the final ranking, a sensitivity analysis is performed after comparing cost and benefits. That analysis tests what changes in assumed values are necessary to impact the final ranking of the alternative.

Relevant Cost Elements

There are five Cost Elements that capture the economic differences relevant to selecting the most cost-efficient maintenance alternative. They are Initial Investment, Preventive Maintenance, Corrective Maintenance, Energy Consumption, and Salvage Value. Following is a description of each cost element and how they impact the total cost.

1. Initial Investment. This is the total investment cost required to implement each maintenance alternative. For this analysis, there is not any initial investment for the status quo alternative. However, for the Primer-Ceramic Paint combination (P-CP) alternative, the initial investment is the

cost of removing deteriorated insulation, sanding the pipes inside the manhole, applying the primer, and applying two coats of ceramic paint.

2. Preventive Maintenance (PM). This cost element captures the cost of doing PM on the carrier pipe inside the manhole. For this analysis, the preventive maintenance includes the cost of performing periodic inspections of the carrier pipe. Under the status quo alternative, the periodic inspections are more difficult than those of the P-CP because the insulation covers the pipe and hence gets in the way of detecting leaks in the carrier pipe. However, the costs of these inspections are considered wash costs in the analysis. The inspections are very similar under both alternatives.

3. Corrective Maintenance (CM). This cost element captures the cost of activities involving breakdown maintenance, including materials and investigative time to determine the cause of a failure or incident. For the Status Quo alternative, it includes the cost of repair by replacement. Under the Status Quo alternative, the life of the HDS is 16 years¹. That is the number of years that takes the Condition Index (CI) of a direct buried drainable dryable HDS fall below 25%. At that point the system is beyond repair and has to be replaced – Repair by replacement.

Under the Primer-Ceramic Paint (P-CP) combination alternative, the time for the CI to fall below 25% is more than 30 years. That is so because protecting the carrier pipe inside the manhole against rust prevents leaks and extra moisture in the manhole which in turn prevents flooding of the manhole. Flooding of manholes is the main cause of failure for HDS² and increases the stress in the pipe segments entering the manhole considerably. In other words, the prevention of leaks in the manhole makes the conditions inside the manhole similar to those of inside manholes with cover raised. The CI for direct buried drainable dryable HDS with raised covers in the manholes, after 30 years is 60% - Good Condition.

4. Energy Consumption. This cost element captures the cost of energy lost in the pipe inside the manhole for each alternative. It is included in the analysis to identify any energy saving or extra cost associated with the P-CP combination. The energy cost is estimated by assuming that the

¹ Engineering Management System For Heat Distribution System; NMD and Associates; Alexandria, VA; August 1995

² Underground Heat Distribution Systems, 1993 Federal Section Conference; May 20-21, 1993; Arlington, VA

boiler plant has an Efficiency Factor (EF) of 0.8 and that the cost of natural gas to the installation is \$0.6 per Therm.

5. Salvage Value. This cost element represents the value of the HDS at the end of the analysis period. Under the Status Quo alternative, at the end of the 20 year analysis the buried pipe still has 12 years of economic life left – 16 years less 4 years. Under the P-CP combination alternative, at the end of the 20 years analysis, the buried pipe still has more than 10 year of economic life left – 30 years less 20 years. Since the economic life left under both alternatives are very similar, the salvage value is a wash cost.

Table C1 below summarizes the above cost element for each alternative

Table C1. Summary of Cost Elements.

Cost Elements	Status Quo	Prime-Ceramic Paint
Initial Investment	No new equipment required	Remove Insulation Sand blast pipes Apply Primer Apply 1 st coat paint Apply 2 nd coat paint
Preventive Maintenance	Null	Null
Corrective Maintenance	Replace Pipes in MH Replace Valves in MH Replace Pipe outside MH	None
Energy Consumption	Energy lost while insulation is saturated with water + energy lost while insulations is dry	Energy lost through ceramic paint.
Salvage Value	Wash	Wash

Source and Derivations of Cost and Benefits

Initial Investment

Neither of the two alternatives considered here requires new equipment or training to be implemented. Therefore, the initial investment cost for both alternatives is \$0.

Under the P-CP combination alternative, applying the paint requires removing old insulation, sanding the pipes, applying the primer, and apply-

ing two coats of the ceramic paint. The costs of those activities have two components labor and materials.

Materials:**1. Ceramic Paint**

Ceramic Paint cost: \$44.5/Gallon

Paint Efficiency Rate for no less than 45 mils dry film = 16
SqFt/Gallon

30 ft of pipe per manhole

4 in. internal diameter = 4.5 external diameter = $4.5 \times 3.14 / 12 =$
1.177 Ft exterior circumference

Total pipe surface in a manhole = $1.177 \times 30 = 35.32$ SqFt

Cost per manhole = $(35.32 \text{ SqFt} / 16 \text{ SqFt/Gallon}) \times \$44.5 \text{ Gallons} =$
\$98.25

Total Ceramic Paint Cost per manhole = \$98.25

2. Primer Paint

Primer Paint cost: \$50/Gallon

Paint Efficiency Rate for pipes for no less than 3 Mils dry film = 200
SqFt/Gal

Total Primer Cost per manhole = $(35.32 \text{ SqFt} / 200 \text{ SqFt/Gall}) \times$
\$50/Gall = \$8.83

Total Primer Cost per manhole = \$8.83

Total Materials Cost per MH = $\$98.25 + \$8.83 = \$107.08$

Labor:

Last September 2005 at Fort Jackson, it took a crew of two people to perform the necessary activities to implement the P-CP alternative in three manholes four days. The labor included sanding the pipes, applying the primer and the two coats of paint.

$$\text{Labor Hours per MH} = (4 \text{ days} * 8 \text{ Hours/Day} * 2 \text{ person}) / 3 \text{ MH} = 21.3 \text{ Hours}$$

$$\text{Hourly Labor Rate} = \$35/\text{Hour in 1996} * 1.48 \text{ escalation factor to 2005} = \$51.8/\text{Hour}$$

$$\text{Labor Cost} = 21.3 \text{ Hours} * \$51.8/\text{Hour} = \$1,103 \text{ per MH}$$

Initial Investment Cost:

$$\text{Initial Investment Cost} = \text{Labor Cost} + \text{Material Cost}$$

$$\text{Initial Investment Cost} = \$1,103 + \$107.8 = \$1,110$$

Preventive Maintenance (PM)

Even though widely accepted preventive maintenance procedures¹ recommend repairing the deteriorated insulation around the carrier pipes in the manholes, lack of manpower at the installations render the practice a low priority status. As a consequence, in order to make this analysis reflect the every day practice at the installation, the PM cost of repairing insulation under the Status Quo alternative is zero.

There is not any preventive maintenance requirement for the combination of primer and ceramic paint. Moreover, the expected life of the paint combination is 30-plus years. Therefore, the estimated cost of preventive maintenance for the P-CP alternative is also zero.

¹ Engineering Management System For Heat Distribution System; NMD and Associates; Alexandria, VA; August 1995

Corrective Maintenance

Under the status quo alternative, the corrective maintenance activities required to repair failed pipes inside and out of the manhole:

- Remove Insulation
- Replace carrier pipes inside MH
- Replace valves inside MH
- Apply new insulation and protective jacket
- Replace buried pipe outside MH

For the average manhole the cost of replacing the insulation according to Engineered Management System for HDS Project Level, NMD and Associates: (1.48 = escalation factor from 1996 prices to 2002 prices)

$$\text{Cost to replace insulation} = 30 \text{ ft} \times \$5.3/\text{ft} \times 1.48 = \$235$$

Under the Status Quo alternative, the life expectancy of the carrier pipe inside the manhole is considered to be only 15 years. After 15 years, the carrier pipes will present considerable pitting and have to be replaced. The cost of replacing the pipes inside the manhole is estimated using NMD report as follows:

From 1996 report the cost for replacing 10 ft section pipe is = 2 Hours @ \$35/Hour + \$178 material = \$247/10 feet. Escalating those prices to 2005 and considering that there are 30 ft pipe inside:

$$\text{Preliminary estimate to replace pipe in MH} = \$247 \times 1.48 \times 3 = \$1,096$$

The above estimate does not take into account the fact that the average manhole has 2 Ts and flanges for 2 Valves that also need to be replaced due to the pitting. It is estimated that the flanges and the Ts add complexity to the replacement and hence increases the cost by 50%

$$\text{Cost to replace pipe inside MH} = \$1,096 \times 1.5 = \$1,645$$

The cost to replace the 2 valves from NMD and associates report and escalated to 2005 is:

$$\text{Cost to replace Valves} = 2 \times \$435 \times 1.48 = \$1,288$$

The cost to replace the direct buried pipe outside MH is also estimated using NMD report. The 1996 cost to replace 4 in. buried per liner ft is \$101. That cost does not include the cost involved in cutting through and then replacing grade level structures like parking areas, sidewalks, curves, and pavement. Considering that there are 500 ft of supply and 500 ft of return pipe, the minimum cost to replace the buried pipe at 2006 price level is:

$$\text{Cost to replace buried pipe} = 2 \times 500 \times 1.48 \times \$101 = \$149,480$$

The total corrective maintenance to replace insulation, pipes, valves, and buried pipes is then:

$$\begin{aligned} \text{Total Corrective Maintenance Cost} &= \$235 + \$1,645 + \$1,288 + \$149,480 \\ &= \$152,648 \end{aligned}$$

Energy Conservation

Under the Status Quo alternative, the pipes inside the manholes has 1.5 in. of mineral fiber insulation wrapped around the pipe and protected with an aluminum jacket with a conductivity factor of 0.024 Btu/Hr-Ft-°F. Under the P-CP alternative, the pipe has at least 45 mil of ceramic paint which has a thermal conductivity of 0.0563 Btu/Hr-Ft-°F. Annex 1 contains detailed estimates of the cost of energy lost through the pipes in the manhole under each alternative. Under the Status Quo alternative, the estimated cost of the annual energy lost in the average manhole is \$150. Under the P-CP combination alternative, the estimated cost of the annual energy lost in the average manhole is \$1,392.

Residual Value

The economic life left at the end of the period of analysis is similar under both alternatives. Hence, the residual value is a wash cost.

Table C2 below summarizes the estimated values for each cost component.

Table C2. Summary of Cost Components.

Cost Elements	Status Quo	Prime-Ceramic Paint
Initial Investment	\$0	\$1,110
Preventive Maintenance	\$0	\$0
Corrective Maintenance	\$152,648 at year 16th	\$0
Energy Consumption	\$150/Year	\$1,392/Year
Residual Value	Wash	Wash

Comparing Cost and Benefits

Introduction

The next two steps in the EA process are (1) the comparison of alternatives and (2) the performance of sensitivity analysis. Alternatives are compared and ranked using three methods: Net Present Value (NPV), Savings-to-Investment Ratio (SIR), and Discounted Payback Period (DPP). These comparisons were done using the ECONPACK 3.0 computer program.

The NPV method is the standard way to compare alternatives in the Army when all the alternatives meet the requirements. The NPV is calculated for each alternative by discounting the value of the costs minus the benefits for each of the twenty years of the analysis and summing them up for a total net (current) value in today's dollars.

SIR is used only to compare investment cost to savings to determine if the investment cost can be recovered through the savings. It is the ratio of savings resulting from using an alternative, instead of using the status quo, to the investment required for implementing the new alternative. When computing SIR, total annual maintenance and operation costs are not discounted, only the difference between annual costs for the two alternatives.

Payback period is the time required for the total accumulating savings of an alternative to offset investment costs. DPP is used in conjunction with SIR. When the SIR is greater than 1, DPP answers the question "How long does it take to recoup the investment cost?"

Comparing Alternatives

The costs estimated in the prior section were used to compute the Life Cycle Cost of each alternative. Annex 2 contains the ECONPACK output file with the results of the analysis. Following is a summary of the results.

Life Cycle Cost of Status Quo

The Life Cycle Cost (LCC) per manhole of the Status Quo alternative over the 20-year period has a

- Cumulative Net Present Value of \$81,916

Life Cycle Cost of Corrosion Protection Primer-Ceramic Based Paint

The LCC per manhole of the Corrosion Protection Primer-Ceramic Based Paint alternative over the 20-year period has a

- Cumulative Net Present Value of \$19,639
- Present Value of Savings of \$63,366
- Present Value of the Initial Investment of \$1,088
- Savings to Investment Ratio of 58.2
- Discounted Payback Period of 16.2 Years

Sensitivity Analysis

Rankings of alternatives may change when some of the assumptions in the analysis change. To test the robustness of the above ranking a test of the sensitivity of the analysis to changes in the estimated savings was performed. The analysis showed that the ranking of alternatives was not sensitive to changes of plus or minus 100% in the cost of the energy losses of the ceramic paint alternative. Figure C2 shows the NPV of each alternative against percentage changes in the cost of energy losses.

Figure C2. Energy Losses Sensitivity Analysis.

However, the analysis showed that the ranking of the alternatives was sensitive to changes in the cost of the major repair of the Status Quo alternative. For the Status Quo alternative to become the least cost alternative, the cost of the major repair has to be reduced by 77.93%. Figure C3 below, shows the NPV of each alternative against percentage changes in the cost of major repairs.

Figure C3. Pipe Replacement Cost Sensitivity Analysis.

Conclusions and Recommendations

Conclusion

An economic analysis of an alternative method of maintaining and repairing the manholes of underground drainable dryable heat distribution systems was performed. The alternative maintenance methodology contemplates coating the carrier pipes inside the manholes with a corrosion protection primer paint and two coats of ceramic based paint. The economic analysis found that the ceramic coating alternative has a net savings of \$63,366 per manhole over a 20-year life cycle and a Savings to Investment Ratio of 58. However, the analysis also found that it takes 16.2 years to recover the initial investment. In addition, the energy analysis also found that the energy losses of the ceramic coating alternative are considerably higher than those of the Status Quo alternative.

Recommendations

Energy conservation is currently a high priority national policy. As a consequence, it may not be politically correct to recommend an alternative that uses more energy than the status quo. Therefore, it is recommended that regular insulation be added on top of the ceramic paint to save energy.

Annex 1: Energy Lost Though Carrier Pipes at Manhole

Heat Transfer

The equations governing the amount of heat transferred through the walls of a pipe by conduction are derived from the Fourier's Law of Conduction¹. For a rectangular wall, the equation is:

$$\dot{Q} = k \times A \times \left(\frac{\nabla T}{\nabla x} \right)$$

Equation C1

¹ DOE Fundamentals Handbook; Thermodynamics, Heat Transfer, and Fluid Flow, Volume 2 of 3; U.S. Department of Energy; Washington, D.C. 20585; June 1992; Page 6.

For a cylinder, the equation is:

$$\dot{Q} = kA \left(\frac{\nabla T}{\nabla r} \right) \quad \text{Equation C2}$$

where:

$\dot{Q}$ = rate of heat transfer (Btu/hr)

A = cross-sectional area of heat transfer (ft²)

Δx = thickness of slab (ft)

Δr = thickness of cylindrical wall (ft)

ΔT = temperature difference (°F)

k = thermal conductivity of slab, or of pipe wall (Btu/ft-hr-°F)

For a pipe with insulation wrapped around, the Fourier's Law has the form¹:

$$\frac{\dot{Q}}{L} = \frac{2\pi(T_m - T_o)}{\left[\frac{\ln\left(\frac{r_2}{r_1}\right)}{k_s} + \frac{\ln\left(\frac{r_3}{r_2}\right)}{k_a} \right]} \quad \text{Equation C3}$$

Where:

r_1 = Inside radius of carrier pipe

r_2 = Outside radius of carrier pipe and inside radius of insulation

r_3 = Outside radius of insulation

k_s = Conductivity of steel

k_a = Conductivity of insulation

T_m = Inside temperature of the pipe

T_o = Outside temperature of the insulation

To estimate the annual cost of the energy lost through the pipe under both scenarios the following assumptions were made for the average manhole:

¹ DOE Fundamentals Handbook; Thermodynamics, Heat Transfer, and Fluid Flow, Volume 2 of 3; U.S. Department of Energy; Washington, D.C. 20585; June 1992; Page 17

- Pipes inside the manhole are horizontal
- Nominal Diameter 4 in.
- 30 ft of steel pipe 5/32 in. thick
- Status Quo insulation thickness = 1.5 in.
- Ceramic Paint insulation thickness ≥ 0.045 in.
- The system operates 24 Hours/Day, 356 Days/Year.
- The temperature of the water inside the carrier pipe is 200 °F
- The boiler Efficiency Factor is 0.8
- The cost of fuel is \$0.6/Therm

Estimating Method

The temperatures were measured at a manhole containing a line insulated with 1.5 in. mineral insulation and a line insulated with a minimum of 45 mils of ceramic paint. The measures were performed 17 April 2006 at 6:00 A.M. The ambient temperature outside the manhole at that time was 66 °F. The 30 years Normal Daily Mean Temperature for Columbia¹, SC is 63.6 °F. As a consequence, the readings are representative of the normal daily mean temperature for the area and can be used to estimate the annual energy losses under both types of insulation.

For the pipe with ceramic paint insulation, temperature on top of the ceramic paint was 153 °F. For the pipe with 1.5 in. mineral wool insulation, the temperature on top of the insulation was 92 °F. The temperature of water in the carrier pipe was known to be 200°F.

For the status quo alternative, the values for Equation 3 are:

$$r_1 = 2 \text{ in.}; r_2 = 2.156 \text{ in.}; r_3 = 3.656 \text{ in.}; k_s = 26.2 \text{ Btu}/(\text{Hr-Ft-}^\circ\text{F});$$

$$k_a = 0.024 \text{ Btu}/(\text{Hr-Ft-}^\circ\text{F}); T_m = 200 \text{ }^\circ\text{F}; T_o = 92 \text{ }^\circ\text{F}$$

T_m = Inside temperature of the pipe

T_o = Outside temperature of the insulation

For the above values, the energy loss in the carrier pipe inside the average manhole per foot of pipe is 31 Btu/Hr-Ft and the annual cost of that energy for the average manhole is \$ 60.

¹ <http://lwf.ncdc.noaa.gov/oa/climate/online/ccd/meantemp.html>

For the ceramic paint alternative, the values for equation 3 are:

$$r_1 = 2 \text{ in.}; r_2 = 2.156 \text{ in.}; r_3 = 2.205 \text{ in.}; k_s = 26.2 \text{ Btu}/(\text{Hr-Ft-}^\circ\text{F});$$

$$k_a = 0.005 \text{ Btu}/(\text{Hr-Ft-}^\circ\text{F}); T_m = 200 \text{ }^\circ\text{F}; T_o = 153 \text{ }^\circ\text{F}$$

T_m = Inside temperature of the pipe

T_o = Outside temperature ceramic paint

For the above values, the energy loss in the carrier pipe inside the average manhole per foot of pipe is 640 Btu/Hr-Ft and the annual cost of that energy for the average manhole is \$ 1,244. Table C3 below contains a summary of the calculations.

Table C3. Summary of Energy Calculations.

Variables	Units	Alternatives	
		Status Quo	Ceramic Paint
T_m	$^\circ\text{F}$	200	200
T_o	$^\circ\text{F}$	92	153
r_1	In.	2	2
r_2	In.	2.156	2.156
r_3	In.	3.656	2.206
k_s	Btu/(Hr-Ft- $^\circ\text{F}$)	26.2	26.2
k_a	Btu/(Hr-Ft- $^\circ\text{F}$)	0.024	0.056
Q/L	Btu/Hr-Ft	31	716
L	Ft	30	30
Q	Btu/Hr	925	21,478
Q_D	Btu/Day	22,189	515,483
Boiler Efficiency	EF	0.8	0.8
Energy Unit Cost	\$/Term	0.6	0.6
Daily Cost	\$/Day	\$ 0.17	\$ 3.87
Annual Cost	\$/Year	\$ 59.91	\$ 1,391.80

The \$60/Year Annual Cost of Energy Lost in the Status Quo was estimated assuming a dry insulation. If the insulation is wet, the losses can increase by a factor of 5¹. Assuming that the insulation is wet 50% of the time, the annual cost is then: Annual Cost of Energy Lost in the Status Quo = \$60 x 5 x 50% = \$150/Year

¹ Engineer Management System for Heat Distribution Systems: Project level; NMD and Associates; Alexandria, VA; February 1996

Annex 2: ECONPACK Output File

DATE GENERATED: 12 May 2006
 TIME GENERATED: 10:57:38
 VERSION: ECONPACK 3.1.0

PrimerCeramicPaintCombination ECONOMIC ANALYSIS

EXECUTIVE SUMMARY REPORT

PROJECT TITLE : CeramicPaint
 DISCOUNT RATE : 4%
 PERIOD OF ANALYSIS : 21 Years
 START YEAR : 2005
 BASE YEAR : 2005
 REPORT OUTPUT : Current Dollars

PROJECT OBJECTIVE:

find the most cost effective way to maintain HDS

ECONOMIC INDICATORS:

ALTERNATIVE NAME	NPV	SIR	DPP	BIR
CERamicPaint	\$19,639	58.2	16.2 YEARS	N/A
Status Quo	\$81,916	N/A	N/A	N/A

ACTION OFFICER: GP
 PHONE NUMBER : 217-356-1348-Ex 202
 EMAIL ADDRESS : gonza.perez@pertan.com
 ORGANIZATION :

ECONOMIC ANALYSIS GRAPH 1
Cumulative Net Present Value

— Status Quo
 - - CERamicPaint

LIFE CYCLE COST REPORT					
CEramicPaint					
YEAR	Major Repair (1)	Utilities (2)	TOTAL ANNUAL OUTLAYS	MIDDLE OF YEAR DISCOUNT FACTORS	PRESENT VALUE
2005	\$1,110	\$0	\$1,110	0.981	\$1,088
2006	\$0	\$1,392	\$1,392	0.943	\$1,312
2007	\$0	\$1,392	\$1,392	0.907	\$1,262
2008	\$0	\$1,392	\$1,392	0.872	\$1,213
2009	\$0	\$1,392	\$1,392	0.838	\$1,167
2010	\$0	\$1,392	\$1,392	0.806	\$1,122
2011	\$0	\$1,392	\$1,392	0.775	\$1,079
2012	\$0	\$1,392	\$1,392	0.745	\$1,037
2013	\$0	\$1,392	\$1,392	0.717	\$997
2014	\$0	\$1,392	\$1,392	0.689	\$959
2015	\$0	\$1,392	\$1,392	0.662	\$922
2016	\$0	\$1,392	\$1,392	0.637	\$887
2017	\$0	\$1,392	\$1,392	0.612	\$853
2018	\$0	\$1,392	\$1,392	0.589	\$820
2019	\$0	\$1,392	\$1,392	0.566	\$788
2020	\$0	\$1,392	\$1,392	0.544	\$758
2021	\$0	\$1,392	\$1,392	0.524	\$729
2022	\$0	\$1,392	\$1,392	0.503	\$701
2023	\$0	\$1,392	\$1,392	0.484	\$674
2024	\$0	\$1,392	\$1,392	0.465	\$648
2025	\$0	\$1,392	\$1,392	0.448	\$623
%NPV	5.54	94.46			
	\$1,088	\$18,550			
DISCOUNTING					
CONVENTION	M-O-Y	M-O-Y			
INFLATION					
INDEX	No	No			
	Inflation	Inflation			
CATEGORY/					
RES SCHD Investment		Recurring			
Costs		Costs			

LIFE CYCLE COST REPORT

CEramicPaint

YEAR	CUMULATIVE NET PRESENT VALUE
------	------------------------------------

2005	\$1,088
2006	\$2,401
2007	\$3,663
2008	\$4,876
2009	\$6,043
2010	\$7,165
2011	\$8,244
2012	\$9,281
2013	\$10,278
2014	\$11,237
2015	\$12,160
2016	\$13,046
2017	\$13,899
2018	\$14,719
2019	\$15,507
2020	\$16,265
2021	\$16,993
2022	\$17,694
2023	\$18,368
2024	\$19,016
2025	\$19,639

4% DISCOUNT RATE, 21 YEARS

PRIMARY ECONOMIC ANALYSIS					
Status Quo Alternative: Status Quo					
Proposed Alternative : CERamicPaint					
Project Year(s)	Recurring Annual Operating Costs Status Quo Alternative	Recurring Annual Operating Costs Proposed Alternative	Differential Costs	Present Value Factor	Present Value of Differential Costs
2005	\$0	\$0	\$0	0.981	\$0
2006	\$150	\$1,392	-\$1,242	0.943	-\$1,171
2007	\$150	\$1,392	-\$1,242	0.907	-\$1,126
2008	\$150	\$1,392	-\$1,242	0.872	-\$1,083
2009	\$150	\$1,392	-\$1,242	0.838	-\$1,041
2010	\$150	\$1,392	-\$1,242	0.806	-\$1,001
2011	\$150	\$1,392	-\$1,242	0.775	-\$963
2012	\$150	\$1,392	-\$1,242	0.745	-\$925
2013	\$150	\$1,392	-\$1,242	0.717	-\$890
2014	\$150	\$1,392	-\$1,242	0.689	-\$856
2015	\$150	\$1,392	-\$1,242	0.662	-\$823
2016	\$150	\$1,392	-\$1,242	0.637	-\$791
2017	\$150	\$1,392	-\$1,242	0.612	-\$761
2018	\$150	\$1,392	-\$1,242	0.589	-\$731
2019	\$150	\$1,392	-\$1,242	0.566	-\$703
2020	\$150	\$1,392	-\$1,242	0.544	-\$676
2021	\$152,798	\$1,392	\$151,406	0.524	\$79,267
2022	\$150	\$1,392	-\$1,242	0.503	-\$625
2023	\$150	\$1,392	-\$1,242	0.484	-\$601
2024	\$150	\$1,392	-\$1,242	0.465	-\$578
2025	\$150	\$1,392	-\$1,242	0.448	-\$556
Totals	\$155,648	\$27,840	\$127,808		\$63,366

PRIMARY ECONOMIC ANALYSIS

Total present value of investment	\$1,088
Plus: present value of existing assets to be used	\$0
Less: present value of existing assets replaced	\$0
Less: present value of proposed alternative salvage value	\$0
Total present value of net investment	\$1,088

Total present value of differential costs	\$63,366
Plus: present value of status quo investment costs eliminated	\$0
Less: present value of status quo salvage value	\$0
Total present value of savings	\$63,366

Savings/Investment Ratio	58.2
Discounted Payback Period	16.2 Years

For Status Quo:

Recurring Costs:	Major Repair
	Utilities

For Proposed Alternative:

Recurring Costs:	Utilities
------------------	-----------

Investment Costs:	Major Repair
-------------------	--------------

LIFE CYCLE COST REPORT					
Status Quo					
YEAR	Major Repair (1)	Utilities (2)	TOTAL ANNUAL OUTLAYS	MIDDLE OF YEAR DISCOUNT FACTORS	PRESENT VALUE
2005	\$0	\$0	\$0	0.981	\$0
2006	\$0	\$150	\$150	0.943	\$141
2007	\$0	\$150	\$150	0.907	\$136
2008	\$0	\$150	\$150	0.872	\$131
2009	\$0	\$150	\$150	0.838	\$126
2010	\$0	\$150	\$150	0.806	\$121
2011	\$0	\$150	\$150	0.775	\$116
2012	\$0	\$150	\$150	0.745	\$112
2013	\$0	\$150	\$150	0.717	\$107
2014	\$0	\$150	\$150	0.689	\$103
2015	\$0	\$150	\$150	0.662	\$99
2016	\$0	\$150	\$150	0.637	\$96
2017	\$0	\$150	\$150	0.612	\$92
2018	\$0	\$150	\$150	0.589	\$88
2019	\$0	\$150	\$150	0.566	\$85
2020	\$0	\$150	\$150	0.544	\$82
2021	\$152,648	\$150	\$152,798	0.524	\$79,996
2022	\$0	\$150	\$150	0.503	\$76
2023	\$0	\$150	\$150	0.484	\$73
2024	\$0	\$150	\$150	0.465	\$70
2025	\$0	\$150	\$150	0.448	\$67
%NPV	97.56	2.44			
	\$79,917	\$1,999			
DISCOUNTING					
CONVENTION	M-O-Y	M-O-Y			
INFLATION					
INDEX	No	No			
	Inflation	Inflation			
CATEGORY/					
RES SCHD	Recurring	Recurring			
	Costs	Costs			

LIFE CYCLE COST REPORT

Status Quo

YEAR	CUMULATIVE NET PRESENT VALUE
------	------------------------------------

2005	\$0
2006	\$141
2007	\$277
2008	\$408
2009	\$534
2010	\$655
2011	\$771
2012	\$883
2013	\$990
2014	\$1,094
2015	\$1,193
2016	\$1,289
2017	\$1,380
2018	\$1,469
2019	\$1,554
2020	\$1,635
2021	\$81,631
2022	\$81,707
2023	\$81,779
2024	\$81,849
2025	\$81,916

4% DISCOUNT RATE, 21 YEARS

COST SENSITIVITY ANALYSIS 1

TITLE: MajorRepairStatusQuo

This sensitivity analysis checks for alternative Status Quo to be ranked least cost as a result of changes in the expense item(s) listed below:

ALTERNATIVE	EXPENSE ITEM(S)
CEramicPaint	** NOTHING CHANGED **
Status Quo	Major Repair

The selected expense items are allowed to vary from a value of -100.00% to .00%

ALTERNATIVE	NET PRESENT VALUE
CEramicPaint	\$19,639
Status Quo	\$81,916

RESULTS:

For alternative Status Quo to be ranked least cost, reduce the selected expense item(s) by more than 77.93%.

COST SENSITIVITY ANALYSIS 1
MajorRepairStatusQuo
Graph of NPV vs. % change in expense items

COST SENSITIVITY ANALYSIS 2

TITLE: Energy Losses for Ceramic Paint

This sensitivity analysis checks for alternative Status Quo to be ranked least cost as a result of changes in the expense item(s) listed below:

ALTERNATIVE	EXPENSE ITEM(S)
-----	-----
Status Quo	** NOTHING CHANGED **
CEramicPaint	Utilities

The selected expense items are allowed to vary from a value of -100.00% to 200.00%

ALTERNATIVE	NET PRESENT VALUE
-----	-----
CEramicPaint	\$19,639
Status Quo	\$81,916

RESULTS:

The ranking of alternatives is insensitive to changes in the selected expense item(s), within the allowable range of variation.

COST SENSITIVITY ANALYSIS 2
Energy Losses for Ceramic Paint
Graph of NPV vs. % change in expense items

REPORT DOCUMENTATION PAGE				Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing this collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.					
1. REPORT DATE (DD-MM-YYYY) June 2007		2. REPORT TYPE Final		3. DATES COVERED (From - To)	
4. TITLE AND SUBTITLE Innovative Corrosion-Resistant Coatings for Heat Distribution Piping at Fort Jackson				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER Corrosion Prevention and Control	
6. AUTHOR(S) Charles P. Marsh, Alfred D. Beitelman, and Ryan J. Franks				5d. PROJECT NUMBER IMA-2	
				5e. TASK NUMBER MIPR5CCERB1011, MIPR5CROBB1012	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army Engineer Research and Development Center Construction Engineering Research Laboratory P.O. Box 9005 Champaign, IL 61826-9005				8. PERFORMING ORGANIZATION REPORT NUMBER ERDC/CERL TR-07-29	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) U.S. Army Installation Management Command Engineering Office, Directorate of Public Works (IMPW-E) 2511 Jefferson Davis Hwy. Arlington, VA 22202				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release; distribution is unlimited.					
13. SUPPLEMENTARY NOTES					
14. ABSTRACT Heat distribution systems are an integral part of military facility and installation infrastructure. These systems include numerous manholes that represent weak points in the overall efficiency, reliability, and service life of heating infrastructure. This report discusses the demonstration of an insulating ceramic paint and primer applied to coat manholes, piping, and appurtenances at Fort Jackson, SC, and the results obtained. The ceramic paint helps to prevent corrosion and heat loss while also significantly mitigating hazardous working conditions. Because these issues are important operational concerns for every military facility, ceramic coatings represent an element of building engineering that should be considered for wider adoption in heat distribution systems.					
15. SUBJECT TERMS coatings, corrosion control, heat distribution systems, manholes, paints, Fort Jackson, SC					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES 71	19a. NAME OF RESPONSIBLE PERSON
a. REPORT Unclassified	b. ABSTRACT Unclassified	c. THIS PAGE Unclassified			19b. TELEPHONE NUMBER (include area code)